

Village of Antioch 2014 Annual Drinking Water Quality Report

ANTIOCH

IL0970050

Annual Water Quality Report for the period of January 1 to December 31, 2014

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

The source of drinking water used by ANTIOCH is Ground Water

For more information regarding this report contact:

Name _____ Bob Zubor Or Dave Hanson _____

Phone ___847-395-1881_____

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

Source of Drinking Water
<p>The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pickup substances resulting from the presence of animals or from human activity.</p>
<p>Contaminants that may be present in source water include:</p> <ul style="list-style-type: none"> - Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. - Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming. - Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses. - Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems. - Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

<p>Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.</p>
<p>In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.</p>
<p>Some people may be more vulnerable to contaminants in drinking water than the general population.</p>
<p>Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).</p>
<p>If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead.</p>

Source Water Information

Source Water Name	Type of Water	Report Status	Location
WELL 1 (20309)	GW	Active___	SOUTHWEST CORNER OF ORCHARD ST AND TOPT AVE.
WELL 10 (01650)	GW	Active___	300 FT WEST OF WELL 9
WELL 2 (20310)	GW	Active___	27 FT SOUTH OF WELL #1
WELL 3 (20311)	GW	Active___	NORTHEAST CORNER OF MCMILLIAN RD AND GAIL ST
WELL 5 (20313)	GW	Active___	S OF RT 173 E OF RR 3 OF
WELL 6 (00633)	GW	Active___	SW COR OF ORCHARD & TOFT
WELL 7 (01053)	GW	Active___	NEXT TO 250000 GALLON ELEVATED TANK
WELL 8 (01648)	GW	Active___	WNW OF SAVAGE AND WHITE ROADS
WELL 9 (01649)	GW	Active___	200 FT NW OF WELL 8

Source Water Assessment

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings. The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop by Village Hall or call our water operator at 847-395-1881. To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>. or pick up a paper copy at the village hall.

Based on information obtained in a Well Site Survey published in 1990 by the Illinois EPA, sixty-two potential sources or possible problem sites were identified within the survey area of Antioch's wells. Furthermore, information provided by the Leaking Underground Storage Tank and Remedial Project Management Sections of the Illinois EPA indicated several additional sites with ongoing remediations which may be of concern. The Illinois EPA has determined that the Antioch's wells #1, #2, #3, #5, #6, #8, #9, and #10 source water is not susceptible to contamination. However, the source water obtained from Well #7 is susceptible to contamination. This determination is based on a number of criteria including; monitoring conducted at the wells; monitoring conducted at the entry point to the distribution system; and the available hydrogeologic data on the wells. In 2008, 2009, and 2010 the Village of Antioch received Non-Compliance Advisories (NCAs) for bacteriological detections in wells #5, #10, and #8 respectively. The facility conducted an investigation on all the wells and determined the cause of the detect(s) to be well maintenance/rehab and sample collection techniques. The facility has corrected the deficiencies at this time. And while the NCA(s) for these wells have now been resolved, monitoring data is continually being tracked in regards to all active potable wells in the Village of Antioch.

Lead and Copper

Definitions:
 Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.
 Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2014	1.3	1.3	0.766	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	2014	0	15	5.9	1	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Water Quality Test Results

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Definitions: The following tables contain scientific terms and measures, some of which may require explanation.

ppb: micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

na: not applicable.

Avg: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

ppm: milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	12/31/2014	1.1	1 - 1.4	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
Haloacetic Acids (HAA5)*	2014	1	0 - 3.3	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2014	8	2.977 - 11.58	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	2014	0.058	0.058 - 0.058	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	2014	1.25	1.25 - 1.25	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Iron	2014	1.3	0.22 - 1.26		1.0	ppm	N	This contaminant is not currently regulated by the USEPA. However, the state regulates. Erosion of natural deposits.
Manganese	2014	6.6	6.6 - 6.6	150	150	ppb	N	This contaminant is not currently regulated by the USEPA. However, the state regulates. Erosion of natural deposits.
Sodium	2014	26	26 - 26			ppm	N	Erosion from naturally occurring deposits: Used in water softener regeneration.
Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination

Combined Radium 226/228	2014	3	3.45 - 3.45	0	5	pCi/L	N	Erosion of natural deposits.
----------------------------	------	---	-------------	---	---	-------	---	------------------------------

Gross alpha excluding radon and uranium	2014	5	4.55 - 4.55	0	15	pCi/L	N	Erosion of natural deposits.
--	------	---	-------------	---	----	-------	---	------------------------------
