

## 2<sup>nd</sup> Water Meter Installation Specifications

### **DEDUCT METERS ARE NOT ALLOWED**

There is no sewer fee charged for consumption on a 2<sup>nd</sup> water meter. Once the installation of a second meter passes inspection, a separate account will be set up by the Utility Billing Department. This account will be billed on an annual basis.

A permit is required. Copy of plumber's license (058 Certificate) and bond (055 Certificate) must be provided with submission of permit application and fees.

### **Underground Irrigation**

A permit is required. Necessary items when submitting permit application:

- Copy of plumber's license (058 Certificate)
- Copy of plumber's bond (055 Certificate)
- Copy of plumber's CCCDI license
- Proposal
- Plat of survey showing the placement of sprinkler heads

Sprinkler heads shall not spray over the sidewalk on to the parkway. If sprinkler heads are to be installed in the parkway, an affidavit stating that the property owner takes all responsibility to remove and/or replace sprinkler heads will be required.

Reduced pressure principle backflow (RPZ) assembly is required on all new lawn sprinkler systems. The RPZ valve may be installed outside or inside. If installed inside, a floor drain must be installed under the valve. An inspection of the RPZ valve is **required** to be done annually by a CCCDI licensed plumber.

